



PAVUS®
FIRE TESTING INSTITUTE

PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek, Czech Republic
Notified Body 1391 Authorization No. SPR/030/4000/24-12 from 16th July 2024

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1391-CPR-2026/0120

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product:

Smoke control damper SEDM-L

**to be used in smoke control systems, in multi-compartment applications,
either up to 600 °C or at fire temperatures**

placed on the market under the name or trade mark of:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic, ID. No. 26718405

and produced in the manufacturing plant:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-8:2011

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This Certificate was first issued on 26th June 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

This Certificate replaces and cancels Certificate of Constancy of Performance No. 1391-CPR-2025/0042 of 1st August 2025 issued by NB 1391.

This Certificate has been issued electronically with digital seal.

Prague 27th July 2026

**PAVUS,
a.s.**

Digitálně podepsal
PAVUS, a.s.
Datum: 2026.08.31
08:24:42 +02'00'



Jan Tripes, MBA
director NB 1391

Technical parameters of the assessed product ^{*)}

Nominal dimensions: Min: 200×430 mm, max: 1200×2030 mm
 Damper blade thickness: 40 mm
 Construction length: 250 mm
 Actuators: Belimo BLE(BEN), 15 N·m / BEE, 25 N·m /BE, 40 N·m
 Control modules: BRC/Mandik MTS: MDCM.1, MDCM.2, MDPM
 AGNOSYS: BRM-10-F, BRM-10-F-ST, BRM-10-F-IP66, IOM-10-F
 MANDGUARD: BRM-20-F, BRM-20-F-ST, BRM-20-F-IP66, IOM-20-F, BRM2-20-F
 MANDIK CORE: SCDI-WT, SCDI-ST, SCDI-IP66, GPIO, SCDI-3P
 BUSTEC BKNE 230-24RB

Aerodynamic characteristics in accordance with EN 1751:2024:

- Leakage through damper body: **Class ATC 3**
- Leakage through damper blade: **Class 3**

Test under pressure: **300 Pa**

Fire resistance classification in accordance with EN 13501-4:2016^{*)}:

EI 120 (vedw-hod) S1000[H]C_{mod}HOT400/30 MAmulti
EI 90 (vedw-hod) S1000[H]C_{mod}HOT400/30 MAmulti

Assessed product performance

Essential characteristics	Requirement clauses in EN 12101-8	Findings
Nominal activation conditions/sensitivity	4.2.1.3	Conforms 4.2.1.3
Response delay (response time)	4.2.1.4	Conforms 4.2.1.4
Operation reliability	4.4.2.2	C _{mod} , loaded
Fire resistance – integrity	4.1.1 a), 4.4.1	E
Fire resistance – insulation	4.1.1 b), 4.4.1	EI
Fire resistance – smoke leakage	4.1.1 c), 4.4.1	EIS
Fire resistance – mechanical stability (under E)	4.1.1 d)	E
Fire resistance – maintenance of the cross section (under E)	4.1.1 e)	E
Fire resistance – high operating temperature	4.1.1 f), 4.4.1	HOT 400/30
Durability – response delay	4.4.2.1	Conforms
Durability – operational reliability	4.4.2.2	C _{mod} , loaded

^{*)} Detailed technical parameters and conditions of the final classification according to EN 13501-4:2016 are stated in the Assessment Report of Performance of the Construction product No. P-1391-CPR-2026/0120 of 27th July 2026.




Jan Tripes, MBA
 director NB 1391